



Product Service

Attestation of Conformity

No. N8A 121705 0017 Rev. 01

Holder of Attestation: **Beijing HollySys Intelligent Technologies Co., Ltd.**
No.2, Di Sheng Middle Road
Beijing Economic Technological Development Area
100176 Beijing
PEOPLE'S REPUBLIC OF CHINA

Product: **Programmable Controller
LX Compact Control System**

Model(s): **LX**

Parameters:

Rated voltage	100-240V~
Rated frequency	50/60Hz
Rated current	0.5A
Protection class	I

Remark:

When installing the equipment, all requirements of the mentioned standard must be fulfilled.

Tested according to:

EN 61010-1:2010/A1:2019
EN IEC 61010-2-201:2018

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 4842025575201

Date, 2026-04-07

(Bin Li)

Page 1 of 1

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.